


LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm					
NAME: DP125RW-WF03-24G30			TYPE:		WEIGHT:
SPEC.:			DIM.:		SERIAL No.:
MFR.:			SUR.:120		Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 83.17 lm/W
MODEL	3000K CRI90	I _{max} (cd)	2754	S/MH(C0/180)	0.78	
NOMINAL POWER(W)	24	LOR(%)	100.0	S/MH(C90/270)	0.76	
RATED VOLTAGE(V)	220	TOTAL FLUX(lm)	1987.9	η UP,DN(C0-180)	0.0,50.6	
NOMINAL FLUX(lm)	1987.88	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,49.4	
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	0.75	
TEST VOLTAGE(V)	36	η down(%)	100.0	CIBSE SHR MAX	0.80	



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators: ZR
 Test Date: 2021-07-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.354
 Humidity: 65.0%
 Test Distance: 8.402m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	2519	2542	2555	2541	2523	2499	2494	2508	0- 10	251.1	251.1	12.6,12.6
20	1859	1915	1931	1908	1853	1822	1810	1861	10- 20	628.2	879.3	44.2,44.2
30	933.3	972.3	972.2	937.4	925.4	888.8	864.1	915.0	20- 30	624.0	1503	75.6,75.6
40	284.6	306.8	292.1	254.1	262.5	254.2	270.4	279.1	30- 40	356.6	1860	93.6,93.6
50	40.64	40.51	39.75	39.39	52.38	51.60	52.98	56.61	40- 50	89.90	1950	98.1,98.1
60	3.975	4.133	3.617	3.220	14.31	14.14	14.28	14.99	50- 60	19.46	1969	99.1,99.1
70	2.688	2.664	2.641	2.649	10.26	10.13	10.14	10.30	60- 70	7.451	1977	99.4,99.4
80	2.740	2.680	2.662	2.686	7.466	7.374	7.351	7.491	70- 80	6.014	1983	99.7,99.7
90	3.356	3.285	3.295	3.367	5.638	5.576	5.566	5.636	80- 90	5.121	1988	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 1921.4 lm

%lum = 96.7%

%lamp = 96.7%

Conical surface Flux(120deg): 1969.3 lm

%lum = 99.1%


%lamp = 99.1%

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:ZR
 Test Date:2021-07-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
 Humidity:65.0%
 Test Distance:8.402m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm		
NAME: DP125RW-WF03-24G30	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:120	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ZR
Test Date:2021-07-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
Humidity:65.0%
Test Distance:8.402m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm		
NAME: DP125RW-WF03-24G30	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:120	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.11	1.08	1.06	1.09	1.07	1.05	1.05	1.03	1.01	1.01	.00	.98	.98	.96	.95	.94
2.0	1.03	.00	.96	1.02	.98	.95	.99	.96	.93	.96	.93	.91	.93	.91	.89	.88
3.0	.97	.92	.88	.95	.91	.87	.93	.89	.86	.90	.87	.85	.88	.86	.83	.82
4.0	.91	.86	.81	.90	.85	.81	.88	.83	.80	.86	.82	.79	.84	.81	.78	.77
5.0	.85	.80	.76	.85	.79	.75	.83	.78	.75	.81	.77	.74	.80	.76	.73	.72
6.0	.81	.75	.71	.80	.74	.70	.78	.73	.70	.77	.73	.69	.76	.72	.69	.68
7.0	.76	.70	.66	.75	.70	.66	.74	.69	.66	.73	.69	.65	.72	.68	.65	.64
8.0	.72	.66	.62	.71	.66	.62	.70	.65	.62	.69	.65	.62	.68	.64	.61	.60
9.0	.68	.63	.59	.68	.62	.59	.67	.62	.58	.66	.61	.58	.65	.61	.58	.57
10.0	.65	.59	.56	.64	.59	.55	.64	.59	.55	.63	.58	.55	.62	.58	.55	.54



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:ZR
 Test Date:2021-07-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
 Humidity:65.0%
 Test Distance:8.402m [K=1.0000]
 Remarks:

WEC AND CCEC

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm					
NAME: DP125RW-WF03-24G30			TYPE:		WEIGHT:
SPEC.:			DIM.:		SERIAL No.:
MFR.:			SUR.:120		Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.176	.100	.032	.169	.096	.031	.156	.090	.029	.145	.084	.027	.134	.078	.025	
2.0	.167	.091	.028	.161	.089	.027	.150	.084	.026	.141	.079	.025	.132	.074	.023	
3.0	.158	.084	.025	.153	.082	.025	.144	.078	.024	.136	.074	.023	.128	.071	.022	
4.0	.150	.078	.023	.146	.076	.023	.138	.073	.022	.131	.070	.021	.124	.068	.021	
5.0	.143	.073	.021	.139	.071	.021	.132	.069	.020	.126	.067	.020	.120	.064	.019	
6.0	.136	.068	.020	.133	.067	.019	.127	.065	.019	.122	.063	.019	.116	.061	.018	
7.0	.130	.064	.018	.127	.063	.018	.122	.062	.018	.117	.060	.017	.113	.058	.017	
8.0	.124	.061	.017	.122	.060	.017	.117	.059	.017	.113	.057	.017	.109	.056	.016	
9.0	.119	.058	.016	.117	.057	.016	.113	.056	.016	.109	.055	.016	.105	.053	.015	
10.0	.114	.055	.015	.113	.054	.015	.109	.053	.015	.105	.052	.015	.102	.051	.015	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.171	.157	.145	.146	.135	.125	.100	.093	.086	.058	.054	.050	.018	.017	.016	
2.0	.156	.133	.113	.133	.114	.098	.091	.079	.068	.053	.046	.040	.017	.015	.013	
3.0	.143	.114	.090	.123	.098	.078	.084	.068	.055	.049	.040	.032	.016	.013	.011	
4.0	.132	.099	.073	.114	.085	.063	.078	.059	.045	.045	.035	.026	.015	.011	.009	
5.0	.124	.087	.060	.106	.075	.052	.073	.053	.037	.042	.031	.022	.014	.010	.007	
6.0	.116	.078	.050	.100	.067	.044	.069	.047	.031	.040	.028	.018	.013	.009	.006	
7.0	.109	.070	.043	.094	.061	.037	.065	.043	.026	.038	.025	.016	.012	.008	.005	
8.0	.104	.064	.037	.089	.055	.032	.062	.039	.023	.036	.023	.013	.012	.008	.004	
9.0	.099	.059	.032	.085	.051	.028	.059	.036	.020	.034	.021	.012	.011	.007	.004	
10.0	.094	.054	.028	.081	.047	.024	.056	.033	.017	.033	.020	.010	.011	.006	.003	

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ZR
Test Date:2021-07-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
Humidity:65.0%
Test Distance:8.402m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm											
NAME: DP125RW-WF03-24G30					TYPE:			WEIGHT:			
SPEC.:					DIM.:			SERIAL No.:			
MFR.:					SUR.:120			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise				Viewed endwise					
x = 2H y = 2H	15.0	15.9	15.2	16.1	16.3	15.2	16.1	15.4	16.3	16.5	
	3H	14.9	15.7	15.1	15.9	16.1	15.0	15.9	15.3	16.1	16.3
	4H	14.8	15.6	15.0	15.8	16.0	15.0	15.8	15.2	16.0	16.2
	6H	14.7	15.4	15.0	15.7	15.9	14.9	15.6	15.2	15.9	16.1
	8H	14.7	15.4	15.0	15.6	15.9	14.9	15.6	15.2	15.8	16.1
	12H	14.6	15.3	15.0	15.6	15.9	14.8	15.5	15.1	15.8	16.1
4H	2H	14.8	15.6	15.0	15.8	16.0	15.0	15.8	15.2	16.0	16.2
	3H	14.6	15.3	14.9	15.6	15.8	14.8	15.5	15.1	15.7	16.0
	4H	14.5	15.1	14.9	15.4	15.7	14.7	15.3	15.0	15.6	15.9
	6H	14.4	15.0	14.8	15.3	15.7	14.6	15.2	15.0	15.5	15.9
	8H	14.4	14.9	14.8	15.3	15.6	14.6	15.1	15.0	15.5	15.8
	12H	14.4	14.9	14.8	15.3	15.6	14.6	15.1	15.0	15.4	15.8
8H	4H	14.4	14.9	14.8	15.2	15.6	14.6	15.1	15.0	15.4	15.8
	6H	14.3	14.7	14.7	15.1	15.5	14.5	14.9	14.9	15.3	15.7
	8H	14.3	14.7	14.7	15.1	15.5	14.5	14.8	14.9	15.3	15.7
	12H	14.3	14.6	14.8	15.1	15.6	14.5	14.8	15.0	15.3	15.7
12H	4H	14.3	14.8	14.7	15.2	15.6	14.5	15.0	14.9	15.3	15.7
	6H	14.3	14.6	14.7	15.1	15.5	14.4	14.8	14.9	15.2	15.7
	8H	14.3	14.6	14.7	15.0	15.5	14.4	14.8	14.9	15.2	15.7
Variations with the observer position at spacings:											
S = 1.0H	+ 3.1 / -10.7					+ 3.1 / -11.1					
1.5H	+ 5.4 / - 9.8					+ 5.4 / -10.1					
2.0H	+ 5.9 / - 4.6					+ 5.9 / - 4.7					

CIE Pub.117, 1988 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = 2.4$)

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ZR
Test Date:2021-07-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
Humidity:65.0%
Test Distance:8.402m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm		
NAME: DP125RW-WF03-24G30	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:120	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	88	81	77	87	81	77	86	81	77	74
0.80	95	89	85	94	89	85	93	88	85	81
1.00	99	94	90	99	93	90	97	93	89	86
1.25	103	98	95	102	98	94	100	96	94	89
1.50	106	101	98	105	101	98	103	99	96	92
2.00	109	104	101	107	103	101	104	101	99	94
2.50	110	106	103	109	105	103	106	103	101	95
3.00	112	108	106	110	107	105	107	104	102	96
4.00	114	111	109	112	109	107	108	106	105	98
5.00	115	113	111	113	111	109	109	107	106	99
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ZR
Test Date:2021-07-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
Humidity:65.0%
Test Distance:8.402m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm		
NAME: DP125RW-WF03-24G30	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:120	Shielding Angle:




C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:ZR
 Test Date:2021-07-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
 Humidity:65.0%
 Test Distance:8.402m [K=1.0000]
 Remarks:

AAI Figure

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm		
NAME: DP125RW-WF03-24G30	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:120	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:ZR
 Test Date:2021-07-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
 Humidity:65.0%
 Test Distance:8.402m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm		
NAME: DP125RW-WF03-24G30	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:120	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:ZR
Test Date:2021-07-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
Humidity:65.0%
Test Distance:8.402m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:224.8V I:0.1110A P:23.90W PF:0.9520 Freq:50.00Hz Lamp Flux:1987.88x1 lm		
NAME: DP125RW-WF03-24G30	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:120	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	1573
L_0~180 (75) av	1944
L_0~180 (85) av	4769
L_90~270 (65) av	1550
L_90~270 (75) av	1923
L_90~270 (85) av	4637
L_45 (65) av	1564
L_45 (75) av	1935
L_45 (85) av	4689

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:ZR
 Test Date:2021-07-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
 Humidity:65.0%
 Test Distance:8.402m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: ZR
Test Date: 2021-07-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.354
Humidity: 65.0%
Test Distance: 8.402m [K=1.0000]
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.354
Humidity:65.0%
Test Distance:8.402m [K=1.0000]
Remarks:

```